


Al Futtaim Exova, & Exova Warringtonfire

EXOVA



**Reaction to Fire Versus Fire Resistance.
Demonstrating a Full Scale Façade Fire Test.
Testing Versus Certification.**

Andy Dean BSc (Hons), MCIQB, FSFE



AIA Middle East

A309


Principles of:
Reaction to Fire vs Fire Resistance,
BS 8414 Full Façade Test Demonstration,
Certification vs Testing

1311. Kuwait.

Andy Dean

October, 2013





Credit(s) earned on completion of this course will be reported to **AIA CES** for AIA members.

Certificates of Completion for both AIA members and non-AIA members are available upon request.

This course is registered with **AIA CES** for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product.

Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.





Copyright Materials

This presentation is protected by US and International Copyright laws.
Reproduction, distribution, display and use of the presentation without written
permission of the speaker is prohibited.



© Exova 2013

Course Description (1)

Fire Resistance versus Reaction to Fire

Reaction to Fire

Reaction to fire tests tend to be small-scale test methods on materials, evaluating – ignitability, flame spread, heat release, smoke development and toxicity.

Samples tend to be small in size (mm rather than m) and relate to the development stages of a fire.

Fire Resistance

These tests are generally used to determine the fire resistance of complete systems (eg. a wall, ceiling, floor structure, jet fan, fire damper, ducting etc). Specimens tend to be large in size (m rather than mm).

They generally evaluate the duration of time that a complete structure will hold back a fire (eg. how long a fire will take before breaking into the adjacent room). Fire resistance tests integrity, and/or insulation and/or load bearing capacity (all measured in minutes)

It relates to performance in a fully developed fire.



Course Description (2)

A Full Scale Façade Test

Video showing a fire-rated façade material versus a non-fire-rated material, when subjected to BS 8414.

(Photographs are shown in the presentation handouts.)

Course Description (3)

Certification versus Testing

Many jurisdictions require products claiming a fire protection performance to be certified by an accredited third party. Third party product certification is a different process to product testing, although testing is usually a part of certification. If you conduct testing, only a test report is issued.

Certification is an independent statement of confidence about the ongoing production of the product, and aims to give the authorities or purchasers of a product confidence that all outputs from the production process meet a consistent level of quality. The outcome of third-party product certification is a performance certificate for a product and inclusion in an online listing of certificated products.

Third party product certification is a longer term process and involves (amongst other processes) random sampling of materials for the test (samples may be selected from stock, the manufacturing line or the open market).

Learning Objectives

At the end of the this course, participants will have been shown:

- 1) The principles of reaction to fire versus fire resistance
- 2) A demonstration of a full-scale fire test
- 3) The principles of testing versus certification



Reaction to Fire (RtF) and Fire Resistance (FR)

- RTF and FR
 - Reaction to fire
 - Fire resistance






Reaction to Fire 1

- Combustibility
 - Ignitability
 - Surface spread of flame
 - Smoke development
 - Toxicity
-
- Usually materials
 - Fire development
 - Various measurement formats
-


Reaction to Fire Testing 1




Reaction to Fire Testing 2



Reaction to Fire Testing 3



Reaction to Fire Testing 4



Reaction to Fire Testing 5






Fire Resistance

- Compartmentation
 - Walls, doors, windows, floors, ceilings, penetration seals
 - Measured in time (temperature, integrity, structural)
 - Usually systems
 - Preventing a fully-developed fire from getting from one compartment into an adjacent one
-


Fire Resistance 1 (vertical furnace)



Fire Resistance 2



Fire Resistance 3



Fire Resistance 4 (horizontal furnace)





Full Scale Fire Testing

- To address
 - Test: BS 8414 – Fire Performance of External Cladding Systems
 - Demonstrate fire-rated versus non-fire rated MCM (metal composite material) ACP (aluminium composite panelling)
-



Residential Block, Sharjah, 2011



Khalidiya Road,
Abu Dhabi



Tamweel Tower,
Dubai





Full Scale Fire Testing

Videos of a façade material under test

- Test: BS 8414 – Fire Performance of External Cladding Systems
-

Test Comparison - Fire-rated after 15 minutes



.....

Test Comparison – Non-fire-rated after 5 minutes





Performance Evaluated

- Flame spread
 - Flame penetration (but not fire resistance)
 - The above aspects should be limited
 - Existing criteria from LPS 1582
-



Relevance

- BS 8414 evaluates spread of flame on façade systems
 - This is **reaction to fire** testing, not **fire resistance**
 - This test is included in the new codes being used in jurisdictions such as the UAE.
 - This is being considered by authorities in the GCC in the development of product standards.
-

- Certification
 - Provides:
 - end-user confidence
 - supplier market entry



Certification – outline and aspects

- Certification is not just testing (there is no such thing as a 'test certificate')
 - Testing is part of the certification process
 - A test produces a test report – this is a factual statement about a single sample
 - Certification links the performance determined by the test, to the ongoing production of the product
 - Certification is undertaken by an accredited organisation (ISO Guide 65) with a specific scope
 - Several types of process – most are highlighted in ISO Guide 67
 - CE Marking is an example (European minimum requirement)
 - Confidence (consumer) and market entry (product supplier)
 - Often called 'listing' in North America – the concept is the same
-



Certification – process elements

1. Application
 2. Document review
 3. Factory Production Control (FPC) audit
 4. Quality Management System (QMS) audit
 5. Product sampling (must be independent)
 6. Type testing
 7. Assessment
 8. Certification decision

 9. Ongoing monitoring (periodical audits and audit testing)
-



This concludes The American Institute of Architects
Continuing Education Systems Course



Exova Warringtonfire

PO Box 34924

Dubai, UAE

+971 50 654 1037

andy.dean@exova.com

www.exova.com



Learning Objectives - Review

You have been shown:

- 1) The principles of reaction to fire versus fire resistance
- 2) A demonstration of a full-scale fire test
- 3) The principles of testing versus certification





Thank You

Al Futtaim Exova, and
Exova Warringtonfire
